

Q & A

From Roofing site visit

These are some questions that were brought up at the roof replacement site visit:

1. What type of material and thickness of the material is being used for the decking?

A. Plywood 5/8" thickness

2. Gutter downspout?

A. Wood boxes with a sheet metal overlay.

3. What gauge metal needed for the down spout boxes?

A. Same as what is being used currently.

Addendum to the Statement of work requirements.

"The Contractor will inspect the roofs for any decking and structural damage and replace as needed."

Correction:

The Contractor will replace all decking and repair any structural damage as needed.